KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-13-00007	**OWNER'S NAME:**	MACDICKEN
DATE:	2/20/2015	**TYPE:**	Frame-Plumb-Mech
TIME STARTED:	12:01 PM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	18-17-02020-0003		

	1. Trusses Ok
	2. Supply @ 80#/15 min - Ok
	3. Waste @ 5#/15 min - Ok
	4. Mechanical Ok
	5. Framing Ok
	6. Fireplace clearances not per manufacturer literature
	7. Install outside air for fireplace
	8. Verify elevation certification

INSTRUCTIONS: Ok to insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____justin.bennett **@co.kittitas.wa.us**