



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00144

OWNER'S NAME: RUBIN

DATE: 11/9/2015

TYPE: Final

TIME STARTED: 2:39 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-17-34010-0002

	1. Blower door test required on building
	2. Any applicable special inspection reports to be documented
	3. Mechanical ok
	4. Plumbing ok
	5. Have L&I final performed
	6. Building final ok
	7. Provide insulation certificate for verification

INSTRUCTIONS: Bring above documentation to office for final sign off on permit card

NEXT INSPECTION: N/A

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506