



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-13-00223                      OWNER'S NAME: DAUGHERTY  
DATE: 7/16/2015                                      TYPE: Re-inspection  
TIME STARTED: 12:20 PM                          INSPECTOR: Justin Bennett  
MAP NUMBER: 18-19-16000-0025

	1. Provide insulation on water heater distribution lines
	2. Provide returns on handrail
	3. Install light/blank @ exterior j-box at East Door
	4. Provide Insulation certificate
	5. Provide blower door testing
	6. Smoke/CO alarm Ok
	7. Mechanical Ok
	8. Provide Septic/Sewer approval
	9. Verify access approval
	10. Maintain fire separation at shop wall per F001

**INSTRUCTIONS:** Complete corrections above/Re-Inspection

**NEXT INSPECTION:** Re-Inspection

RE-INSPECTION FEE DUE?     NO     YES    \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506