



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00239

OWNER'S NAME: CLARK

DATE: 10/21/2014

TYPE: Final

TIME STARTED: 3:57 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-02053-0003

1. kitchen sink not installed
2. kitchen and bath floors need to be sanitary. Must be sealed or painted
3. safety glass required within 24"of doors. (window next to french door)
4. A window film can be obtained and applied to the window. call with questions
5. access and sewer not signed off on permit. Bring to building dept. for approval

INSTRUCTIONS: complete above, call for re-inspection

NEXT INSPECTION: re-inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506