INSPECTION REPORT

BP-13-00357

PERMIT NUMBER:

OWNER'S NAME: CATLIN

DATE:		5/19/2015	TYPE:	Framing
TIME STARTED:		1:42 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:		21-14-34040-0016		
	1. Approved Plans Not On Site.			
	2. Not Able to Verify Footing Width/Depth.			
	3. Interior Framing OK.			
INSTRUCTIONS: OK to Cover Interior. Excavate Footings for Depth/Width Verification.				
NEXT INSPECTION: Final				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
	jeremy.haberman @co.kittitas.wa.us			
		CTION REQUEST LINE: <u>www.co.k</u> 11 N Ruby Street Suite 2 Ellensburg		