



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00367

OWNER'S NAME: ELLIS

DATE: 3/21/2016

TYPE: Final

TIME STARTED: 11:35 AM

INSPECTOR: Amber Green

MAP NUMBER: 20-14-24050-0106

	1. Exterior siding must be complete.
	2. Provide blower door test results.
	3. Final water/sewer connection letter from Suncadia.
	4. Provide final fire sprinkler approval for casita.

INSTRUCTIONS: Complete Above, call for re-inspection.

NEXT INSPECTION: Re-Final

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [amber.green@co.kittitas.wa.us](mailto:amber.green@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506