



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00367

OWNER'S NAME: ELLIS

DATE: 7/11/2016

TYPE: Final

TIME STARTED: 1:29 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-24050-0106

1. Drawings not on site
2. Verify fire sprinkler final
3. Blower door not complete/Posted @ electrical panel
4. Provide insulation and weather stripping @ floor access
5. NOTE: Final inspection could not be performed due to lack of drawings
6. Complete exterior weather tight membrane

INSTRUCTIONS: Complete corrections above/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506