



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00367

OWNER'S NAME: ELLIS

DATE: 7/15/2016

TYPE: Final

TIME STARTED: 11:02 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-24050-0106

1. NOTE: PERMIT NUMBER PERTAINS TO BUNKHOUSE.
2. NOTE: PERMIT WILL EXPIRE 7/28/16.
3. BLower Door Test Not Provide.
4. Crawlspace Access Not Insulated.
5. Exterior Not Weather Tight.
6. NOTE: Inspector Will Confirm Loft Access Permitted. Fall Protection May Be Required.
7. Prior Corrections Not Addressed. RE FEE DUE.
8. NOTE: Photos Saved to "T" Drive.

INSTRUCTIONS: Complete Above. Pay ReInspection Fee.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?

☐

NO

☒

YES

\$ 86.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506