INSPECTION REPORT

PERMIT NUMBER:	BP-13-00369	OWNER'S NAME:	ELLIS
DATE:	5/4/2015	TYPE:	Insulation
TIME STARTED:	1:18 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-14-24050-0106		
1. R-15 on exterior walls. 2" Roxul board to be used on exterior			
2. house insulation ok			
3. apply vapor barrier or use PVA primer			
4. garage insulation ok in wine room			
INSTRUCTIONS: ok to cover			
NEXT INSPECTION: hydronics/fireplace			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
<u>iessica.contratto</u> @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			