



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-13-00397

OWNER'S NAME: GRINNELL

DATE: 7/10/2014

TYPE: Rough-in plumbing

TIME STARTED: 9:50 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-16-26000-0038

	DVW not at min. of 5#
	sprinkler system at 70#
	H2O at 80# OK

**INSTRUCTIONS:** pressurize DWV to minimum of 5#, Re-inspect or see before insulation

**NEXT INSPECTION:** re-inspect or framing/mechanical

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506