



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00051

OWNER'S NAME: CITY OF ELLENSBURG

DATE: 2/1/2016

TYPE: Final

TIME STARTED: 1:43 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-18-25068-0046

1. Plumbing Final OK
2. Mechanical Final OK.
3. Fire Marshall Building Final Not Completed.
4. No Record of Permit for Generator. No Record of Fire Marshall Final for Generator.
5. Unable to Verify L&I Final. Provide Copy of Inspection Report or Permit Number.

INSTRUCTIONS: Complete Above. Call for ReInspection.

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506