



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00092

OWNER'S NAME: RADICH

DATE: 11/7/2014

TYPE: Frame-Plumb-Mech

TIME STARTED: 10:48 AM

INSPECTOR: Amber Green

MAP NUMBER: 18-19-29054-0003

	1. Engineer stamped truss sheets are not on site.
	2. Floor plans have changed added rooms.
	3. Kitchen has been plumbed and wired for, not on plans.
	4. You may not use or occupy this structure until finalized.

INSTRUCTIONS: Submit updated plans for review. DO not Cover. We cannot perform an inspection until this building is cleared out.

NEXT INSPECTION:

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

● **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 ●
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ● Main Office Line: 509-962-7506