## **INSPECTION REPORT**

PERMIT NUMBER:	BP-14-00092	OWNER'S NAME:	RADICH
DATE:	12/8/2014	TYPE:	Mechanical and plumbing
TIME STARTED:	2:25 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	18-19-29054-0003		
1. truss b	racing on C1 on south e	nd	
2. DWV on stack/15-ok			
3. H2O is live- ok			
4. gas not at 15#			
5. framing ok			
INSTRUCTIONS: complete truss brace and put gas on test. see at insulation. ok to insulate			
NEXT INSPECTION: insulation			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jessica.contratto @co.kittitas.wa.us			
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>			