



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00092 OWNER'S NAME: RADICH
DATE: 1/7/2015 TYPE: Insulation
TIME STARTED: 12:17 PM INSPECTOR: Amber Green
MAP NUMBER: 18-19-29054-0003

	1. Truss bracing not complete per previous inspection report.
	2. Gasline test still too low. Must be a minimum of 15 psi.

INSTRUCTIONS: Compete Above. Re-Fee and then Re-Call Inspection.

NEXT INSPECTION: Re-Inspection after Re-Fee paid.

RE-INSPECTION FEE DUE? NO YES \$ 65.00 _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

● **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 ●
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ● Main Office Line: 509-962-7506