



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00096 OWNER'S NAME: KCFD #7
DATE: 10/28/2014 TYPE: Slab
TIME STARTED: 1:50 PM INSPECTOR: Amber Green
MAP NUMBER: 20-14-26040-0005

	1. Hydronics (100#/30 min) - OK
	2. 4" and 6" slab re-bar OK
	3. Trench drains - OK

INSTRUCTIONS: OK to Pour 4" and 6" slabs.

NEXT INSPECTION: 8" slab

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506