



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00096 OWNER'S NAME: KCFD #7
 DATE: 4/23/2015 TYPE: Final
 TIME STARTED: 2:02 PM INSPECTOR: Justin Bennett
 MAP NUMBER: 20-14-26040-0005

1. Install electrical wall blank in BR 6
2. Install electrical blank on East wall behind UH-3
3. Provide electrical blanks in both bathrooms @ overhead J Box
4. Program bathroom sensors to turn on vanity/overhead/exhaust fan upon entry
5. Adjust both bathroom doors to close
6. Secure light in bedroom 2
7. Provide Balancing report for final
8. Verify L&I final sign off
9. Provide CO detectors in main hallway
10. Verify seismic requirements for HVAC/Plumb systems - Pending
11. Verify Fire Marshal Final sign off

INSTRUCTIONS: Special inspections/Access/Septic/Storm water OK

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ justin.bennett@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506