KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00111	**OWNER'S NAME:**	ZEVERLY
DATE:	11/1/2016	**TYPE:**	Re-inspection
TIME STARTED:	11:20 AM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	17-19-32040-0008		

1. Shear Nailing Corrections OK.
2. ABWP 'G' at Garage not per A/G-101 - Double sill, strap @ header
3. 46" BWP 'A' at South Porch Nailing Tightened to 4" O.C. OK Per 'MF' 11-1-2016

INSTRUCTIONS: OK to Cover Exterior. Strap and Plate Correction to Be Seen at Plumbing

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____jeremy.haberman **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506