



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00129 OWNER'S NAME: CALHOUN
 DATE: 1/16/2015 TYPE: Insulation
 TIME STARTED: 12:09 PM INSPECTOR: Jessica Contratto
 MAP NUMBER: 17-17-01052-0001

1. DWV not on test to 10 height
2. H2O at 70#-ok
3. Trusses ok
4. framing ok
5. need to review fire separation options
6. can lights and washer box cannot penetrate fire separation

INSTRUCTIONS: ok to insulate exterior walls. see Waste on stack test at next inspection

NEXT INSPECTION: insulation/fire separation

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contrato@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506