KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00172	**OWNER'S NAME:**	THE PASS LLC
DATE:	10/7/2014	**TYPE:**	Exterior shear
TIME STARTED:	1:05 PM	**INSPECTOR:**	Amber Green
MAP NUMBER:	22-11-04055-0031		

	1. 3x sill plate missing at P2 shearwalls - obtain engineers approval/fix.

INSTRUCTIONS: OK TO COVER EXTERIOR.

NEXT INSPECTION: FRAME/PLUMB/MECH

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____amber.green **@co.kittitas.wa.us**