



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00236

OWNER'S NAME: CHILDERS

DATE: 11/21/2014

TYPE: Rough-in plumbing

TIME STARTED: 10:54 AM

INSPECTOR: Amber Green

MAP NUMBER: 20-14-13050-0043

	1. Will see cleanout at kitchen sink at final.
	2. DWV (7#/15min) - OK H2O (50#/15min) - OK

INSTRUCTIONS:

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506