KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00318 **OWNER'S NAME:** Watt

DATE: 9/3/15 **TYPE:** Shearwalls

TIME STARTED: 3:30PM **INSPECTOR:** Bennett

1	Complete HD install (verify @ framing)
2	Ext. Shear OK
3	Install galvanized nails in mud sill
4	OK to cover once complete

INSTRUCTIONS: Complete above/ Once complete ok to Cover

NEXT INSPECTION: Mech/Plumb

RE-INSPECTION FEE DUE? ☒ NO ☐ YES $ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett **@co.kittitas.wa.us**