



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00381 **OWNER'S NAME:** PARR
DATE: 4/8/2015 **TYPE:** Final
TIME STARTED: 1:10 PM **INSPECTOR:** Jeremy Haberman
MAP NUMBER: 20-15-19050-0046

	1. Grade Needs to be 6" Below Siding, Grade Must Slope Away From Structure 6" Fall in 10.
	2. Garage Fire Door Must Be Self Closing.
	3. Weatherproof Kennel Wall on Exterior.
	4. Blower Door/Duct Leakage Test Needed.

INSTRUCTIONS: Complete Above. Reinspect. (4/8/15 PM Manual Dampers Not Permitted per County Code.)

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506