KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00429	**OWNER'S NAME:**	HAUENSTEIN
DATE:	12/4/2015	**TYPE:**	Final
TIME STARTED:	10:20 AM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	20-14-12052-0010		

	1. Double Sided Shear OK.
	2. Complete Fire Marshall Final
	3. Complete Siding at Exterior.
	4. Blower Door Test Not Complete.
	5. Landings at Exterior Doors. 36x36. Compact Gravel Not Less than 7 3/4" Below Door.
	6. Tension Self Closing Hinges. Trim On. Fire Caulk.
	7. Complete Handrail at Stairs.

INSTRUCTIONS: Make Corrections Above

NEXT INSPECTION: Final.

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____jeremy.haberman **@co.kittitas.wa.us**