KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00503	**OWNER'S NAME:**	FORTUNE CREEK LLC
DATE:	3/4/2015	**TYPE:**	Framing and mechanical
TIME STARTED:	12:19 PM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	19-15-07061-0018		

	1. 3 ply girder on upper level not per truss sheets
	2. Install blocking at bracing at ES2 trusses
	3. Anchor bolt and plate not installed at center wall in garage
	4. Point load framing not per plans
	5. Install strap at beam in dining room
	6. Attic access not installed per plans
	7. Stairway height to lower level is not 80"
	8. Mechanical Ok
	9. Fireplace manual not on site

INSTRUCTIONS: Complete items above and call for reinspection

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____justin.bennett **@co.kittitas.wa.us**