KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00521	**OWNER'S NAME:**	WOODWARD
DATE:	1/20/2015	**TYPE:**	Insulation
TIME STARTED:	1:10 PM	**INSPECTOR:**	Lou Whitford
MAP NUMBER:	20-15-19050-0163		

	1. Fireplace not installed.
	2. DWV Minimun 5#. Test at 3#.
	3. Insulation OK.

INSTRUCTIONS: Do Not Cover. Complete Corrections.

NEXT INSPECTION: Re-Inspect.

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____lou.whitford **@co.kittitas.wa.us**