KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00566

OWNER'S NAME: COFFMAN

DATE: 6/15/2016

TYPE: Final

TIME STARTED: 12:25 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29051-0095

1. Fire Door at Garage Not Self Closing.
2. Blower Door Test Result Not Onsite.
3. CO Detector Required at Bedroom 2/3 Hall.
4. Range Vent Not Functioning
5. Fireplace Not Functioning
6. Patio Fire Pit Not Installed/Not Functioning.
7. Fire Marshall Final Not Complete.
8. Sewer Letter Provided.
9. Energy Credits Not Verified.

INSTRUCTIONS: Complete Above

NEXT INSPECTION: Re Inspection.

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____jeremy.haberman **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506