



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00624

OWNER'S NAME: STRUELI

DATE: 1/16/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 10:23 AM

INSPECTOR: Lou Whitford

MAP NUMBER: 20-14-29051-0004

1. Plumbing at 15#/15 - ok
2. DWV at 5#/15 - ok
3. Gas at 15#/15 - ok
4. Install H1 clips at exterior/entry canopy
5. Tempered window at main entry
6. Tempered window at stair landing
7. Required plan revision for covered porch Option 2
8. Mechanical OK

INSTRUCTIONS: Need ladder to confirm bevel at beam

NEXT INSPECTION: Permit for option 2 / OK to insulate walls only

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ justin.bennett@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506