INSPECTION REPORT

PEKIVI	II NUMBER:	BP-14-00624	OWNER'S NAME:	STRUELI	
DATE:		1/20/2015	TYPE:	Insulation	
TIME STARTED:		10:46 AM	INSPECTOR:	Lou Whitford	
MAP NUMBER:		20-14-29051-0004			
	1. Insulat	ion OK.			
		2. H2 Installation at Covered Porck OK.			
	3. Tempered Correction not Complete.				
	4. Tempered Windows Required at Entry Door and at Stair Landing.				
	5. Covered Porch Design Option 2 OK. Plan Review Worksheet on site. Permit # BP-14-00624				
INSTRUCTIONS: Ok to Cover					
NEXT INSPECTION: Final w/Corrections.					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	lou.whitford @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 					