KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00637	**OWNER'S NAME:**	SINCLAIR
DATE:	4/29/2015	**TYPE:**	Shearwalls
TIME STARTED:	12:16 PM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	18-18-21040-0001		

	1. Install portal frame straps per detail from top plate
	2. Correct nailing at North wall (nails are not embedded in stud)
	3. Ok to cover exterior

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____justin.bennett **@co.kittitas.wa.us**