## **INSPECTION REPORT**

BP-14-00705

**PERMIT NUMBER:** 

OWNER'S NAME: CONNELLY/KANWETZ

DATE:		3/2/2015	TYPE:	Mechanical and plumbing	
TIME STARTED:		9:17 AM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:		17-18-08000-004	18		
	1. Gas Line not On Test.				
2. DWV OK. 6#/15min.					
	3. Suppl	3. Supply OK. 86#/15/min.			
	4. Plumbing OK.				
	5. Bath Fans Not Installed.				
	6. Fireplace Manual Not Accesible.				
INSTRUCTIONS: Complete Above.					
NEXT INSPECTION: Framing.					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	jeremy.haberman @co.kittitas.wa.us				
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926</li> <li>Main Office Line: 509-962-7506</li> </ul>					