



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00705

OWNER'S NAME: CONNELLY

DATE: 3/6/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 11:49 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-08000-0048

| |
|--|
| 1. Previous Corrections Not Complete. |
| 2. Gas Line OK. 18#/15Min. |
| 3. Framing Inspection Can Not be Completed Until Electrical is Complete. |
| 4. Stamped Truss Sheets will Need to be Onsite for Framing Inspection |
| 5. Fireplace Manual Not Accesible. |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |
| |

INSTRUCTIONS: Make Corrections Above.

NEXT INSPECTION: Reinspect

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506