



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-14-00705

OWNER'S NAME: CONNELLY

DATE: 3/27/2015

TYPE: Framing

TIME STARTED: 11:05 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-08000-0048

1. Trusses OK.
2. Framing OK.
3. Exhaust Ducting OK.
4. Heat Ducting Previously OK.
5. Add Insulation Collar at Fireplace Flu.

**INSTRUCTIONS:** Make Corrections Above. OK to Insulate.

**NEXT INSPECTION:** Insulation.

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506