

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00708	OWNER'S NAME:	CASCADE VIEW INC
DATE:	11/17/2014	TYPE:	Footings
TIME STARTED:	2:07 PM	INSPECTOR:	Lou Whitford
MAP NUMBER:	18-18-27071-0139		

1. ROCK BOULDERS ARE NOT ALLOWED IN FTG TO SUPPORT REBAR			
2. USE CONCRETE REBAR "CRADLES" FOR REBAR SUPPORT			
3. OK TO POUR WHEN REMOVED			
4. OK SLAB INSULATION			
INSTRUCTIONS:			
NEXT INSPECTION: SHEARWALLS			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
lou.whitford @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			