



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00708 OWNER'S NAME: CASCADE VIEW INC
 DATE: 3/3/2015 TYPE: Frame-Plumb-Mech
 TIME STARTED: 10:25 AM INSPECTOR: Justin Bennett
 MAP NUMBER: 18-18-27071-0139

1. Hanger nailing not complete in Bonus Rm
2. Complete truss nailing at top plate
3. Provide trimmers and window ledge per plans
4. Provide (3) 2x6 under two ply truss in third bedroom
5. Waste @ 8#//15 min - Ok
6. Supply @ 42# - Must be at 50# min
7. Mechanical Ok
8. Install blocking in Den @ girder load
9. Install studs at stair door per plans
10. Nail beams at beam pockets per plan

INSTRUCTIONS: Complete items above, call for reinspection

NEXT INSPECTION: Reinspection

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ justin.bennett@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506