INSPECTION REPORT

TYPE:

INSPECTOR:

PERMIT NUMBER:

TIME STARTED:

DATE:

BP-14-00708

3/5/2015

4:20 PM

OWNER'S NAME: CASCADE VIEW INC

Re-inspection

Justin Bennett

мар number: 18-18-27071-0139	
1. Water @ 50#/15 min - OK	
2. Corrections Ok	
3. Relocate second floor door in interior shear wall	
INSTRUCTIONS: Complete items above/Ok to insulate	
NEXT INSPECTION: Insulation	
RE-INSPECTION FEE DUE? NO YES \$	
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION	
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:	
justin.bennett @co.kittitas.wa.us	
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 	