



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER:	BP-14-00734	OWNER'S NAME:	LYTLE FAMILY TRUST
DATE:	2/17/2015	TYPE:	Slab plumbing
TIME STARTED:	11:08 AM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	19-14-03000-0056		

	1. Slab Plumbing OK. DWV 5#/15min.
	2. Ext. Shear Nailing OK. Verify Clips per Shear Schedule at Framing.
	3. Double Sided Shearwall Not Complete at Time of Inspection.
	4. Fireplace Not Roughed In at Framing. Verify Rough Prior to OK to Cover.

**INSTRUCTIONS:** Complete Above

**NEXT INSPECTION:** Plumb/Frame/Mech

RE-INSPECTION FEE DUE?      NO      YES     \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506