



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00751

OWNER'S NAME: NEW SUNCADIA LLC

DATE: 7/17/2015

TYPE: Mechanical and plumbir

TIME STARTED: 11:50 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29051-0018

1. H2O is live-ok
2. DWV not on test
3. gas line not on test
4. provide draftstop at attic duct penetration above garage
5. insulation shields on B-vent for water heater
6. fireplace ok
7. hole in floor below furnace alcove needs to be covered and sealed. fire protection may be required

INSTRUCTIONS: complete above

NEXT INSPECTION: re-inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506