

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00786	OWNER'S NAME:	BACK COUNTRY RESOURCES LLC
DATE:	4/20/2015	TYPE:	Slab plumbing
TIME STARTED:	9:38 AM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	19-15-07061-0015		

1. In Slab Plumbing Not at Required PSI. DWV @ 0 PSI			
INSTRUCTIONS: DO NOT POUR.			
NEXT INSPECTION: Re Inspect.			
RE-INSPECTION FEE DUE? V YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jeremy.haberman @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506 			
+11 N. NUDY SUCCE, SUICE 2, LITENSDUIG, WA 30320 ♥ WIdill Office Lifte. 305-302-7300			