INSPECTION REPORT

PERMIT NUMBER:	BP-14-00813	OWNER'S NAME:	UNIONVILLE RANCH
DATE:	3/11/2015	TYPE:	Framing
TIME STARTED:	2:12 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	19-17-06040-0009		
1. strap b	eams to top plate in bed	room	
2. LU24 hangers at porch overhang			
3. plumbing in remodel not installed yet			
4. obtain letter for approval of non PT lumber for siding furr out			
INSTRUCTIONS: ok to cover soffits. Ok to insulate addition			
NEXT INSPECTION:	olumbing/bedroom insulation		
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jessica.contratto @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 ◆ 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506 			