



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00813

OWNER'S NAME: UNIONVILLE RANCH

DATE: 3/24/2015

TYPE: Rough-in plumbing

TIME STARTED: 2:39 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-17-06040-0009

	1. insulation ok
	2. DWV on stack-ok
	3. H2O at 80#-ok
	4. paint on copper treatment used on furring strips

INSTRUCTIONS: ok to cover

NEXT INSPECTION: final

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506