



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00841

OWNER'S NAME: LITTLEFIELD

DATE: 4/28/2017

TYPE: Final

TIME STARTED: 10:21 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-13-11050-0056

1. Corrections ok
2. Insulation ok via photos
3. Handrail to be between 34"-38" to top of rail, measured vertically of the nosing of the tread. Handrails must return to wall at ends
4. Complete WUIC inspection from fire marshal. Can be scheduled through inspection request line

INSTRUCTIONS: Complete above

NEXT INSPECTION: Re-inspect

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506