KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14	**OWNER'S NAME:**	SMITH
DATE:	7/31/2014	**TYPE:**	Shearwalls
TIME STARTED:	12:30pm	**INSPECTOR:**	Jessica Contratto
MAP NUMBER:	20-13-11050-0044		

	Window added to bathroom upstairs in a shearwall. Get engineer approval or revision for A1
	shearwall
	Floor framing inspection still not completed
	top edge of sheathing below "heat pump" painted on wall not nailed

INSTRUCTIONS: complete above. call for re-inspection. Have revised plans on site per discussion with Amber

NEXT INSPECTION: re-inspect shear, floor framing

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____jessica.contratto **@co.kittitas.wa.us**