KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00024	**OWNER'S NAME:**	Jackson
DATE:	3/27/2015	**TYPE:**	Rough-in plumbing
TIME STARTED:	2:51 PM	**INSPECTOR:**	Jessica Contratto
MAP NUMBER:	20-14-28061-0002		

	1. H20 is live-ok
	2. DWV on stack
	3. cracked and leaking cleanout tee in laundry room
	4. nail plate where required
	5. leaking fitting where pex connects at dishwasher vent
	6. R-21 insulation and vapor barrier on exterior walls behind showers

INSTRUCTIONS: make corrections and call for re-inspection on DWV

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____jessica.contratto **@co.kittitas.wa.us**