KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00027	**OWNER'S NAME:**	DEHERRERA
DATE:	4/17/2015	**TYPE:**	Rough-in plumbing
TIME STARTED:	9:13 AM	**INSPECTOR:**	Justin Bennett
MAP NUMBER:	17-19-34053-0003		

	1. Waste not on test
	2. Supply @ 50#/15 mins - Ok

INSTRUCTIONS: Call for re-inspection

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____justin.bennett **@co.kittitas.wa.us**