



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00107

OWNER'S NAME: SANDBERG

DATE: 8/31/2015

TYPE: FRAMING / SLAB PLUMBING

TIME STARTED: 10:39 am

INSPECTOR: HABERMAN

	DWY OK STAIR
	SUPPLY OK SUPPLY @ 65 [°] /15 min.
	PLUMBING OK.
	MECHANICAL:
	GAS LINE NOT INSTALLED
	FIREPLACE NOT INSTALLED
	VENTED WINDOWS NOT INSTALLED
	TRUSSES OK
	GARAGE HEADER ↓ R3 (RH) WINDOWS NOT 4x12 DF PER PLAN.
	HDV'S MUST CONNECT TO (2) FULL HEIGHT STUFS.

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506