KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00133

OWNER'S NAME: LANPHERE

DATE: 5/31/2016

TYPE: Mechanical

TIME STARTED: 11:30 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-26000-0001

1. NOTE: PRIOR SHEAR CORRECTION NOT ADDRESSED
2. Address Not Posted.
3. Plans/Permit Not Onsite.
4. Gas Line at 20#/15min OK. Tag Attached to Test Gauge.
5. Mechanical Supply Runs Not Complete.
6. BAth Fans Not Installed/Not Connected. Condition Exists Throughout.

INSTRUCTIONS: Complete Mechanical Installation. Make Shear Corrections.

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$ _____**

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____jeremy.haberman **@co.kittitas.wa.us**

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506