KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00155	**OWNER'S NAME:**	BECKER
DATE:	10/22/2015	**TYPE:**	Framing
TIME STARTED:	2:25 PM	**INSPECTOR:**	Jeremy Haberman
MAP NUMBER:	20-15-29050-0099		

	1. Clear Combustable Material From Chimney Chase and Seal Drsftstop at Floor to Floor.
	2. Verify Epoxy Imbed of HDU Bolts at Garage
	3. Connect Drag Strut at Top of Wall Adjacent to Fire Place.
	4. Verify Return Air Intake in Loft Over Garage after Insulation.
	5. Interior Shear OK.

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation/Corrections

RE-INSPECTION FEE DUE? ☑ **NO** ☐ **YES** **$** _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____jeremy.haberman **@co.kittitas.wa.us**