KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

| | | | |
|---|---|---|---|
| **PERMIT NUMBER:** | BP-15-00195 | **OWNER'S NAME:** | BECHT |
| **DATE:** | 5/25/2016 | **TYPE:** | Final |
| **TIME STARTED:** | 11:53 AM | **INSPECTOR:** | Jessica Contratto |
| **MAP NUMBER:** | 19-15-09058-0004 | | |

1. Vapor line to heat pump must be insulated with appropriate insulation(Armaflex)
2. Backfill rear deck corner post footing
3. Seal all penetrations in garage separation wall and along gap at top plate around perimeter of garage and top plate penetrations at fire separation
4. Strap water heater and insulate water lines
5. Seal electrical penetration and others through ceiling in mechanical room
6. Septic not finaled yet
7. 36" tall guards needed at attic strage in garage. Solid sheathing acceptable
8. Blower door test results not on site
9. Energy credits ok

**INSTRUCTIONS:** Complete above, call for re-inspection

**NEXT INSPECTION:** re-inspection

**RE-INSPECTION FEE DUE?** ☑ **NO** ☐ **YES** **$ _____**

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:_____jessica.contratto **@co.kittitas.wa.us**

**INSPECTION REQUEST LINE: 509-962-7694**

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506