



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00215

OWNER'S NAME: WEST

DATE: 11/17/2015

TYPE: Rough-in plumbing

TIME STARTED: 9:32 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-24050-0517

	1. H2O at 80#-ok
	2. DWV not on test
	3. Gas not on test, as a note
	4. Can island sink drain be looped to tie into sink drain at exterior wall??

INSTRUCTIONS: Have waste on test for next inspection

NEXT INSPECTION: re-plumb/mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506