



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00215

OWNER'S NAME: WEST

DATE: 1/26/2016

TYPE: Re-inspection

TIME STARTED: 11:02 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-24050-0517

1. Gas @ 25#/15 mins - Ok
2. Engineer letter for shearwalls/holddowns/outlookers Ok
3. Fireplace draftstop installed (verify fire blocking & FSK @ insulation)
4. Verify hold downs & panel blocking in master bedroom @ insulation
5. Install hangers @ J07 truss in Master (verify @ insulation)
6. Complete hangers above furnace (verify @ insulation)
7. Install CS strap @ back porch beam in kitchen
8. Other correction items not listed below - Ok

INSTRUCTIONS: Complete above/Verify @ insulation (Areas requiring verification will need to be visible)

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506